Throttle valve type ED, throttle restrictor check valve type RD and RDF

Product documentation

Operating pressure pmax: 500 bar Flow rate Qmax: 130 lpm



D 7540 11-2014-1.3



© by HAWE Hydraulik SE.

The forwarding and reproduction of this document, as well as the use and communication of its contents, are forbidden unless expressely permitted.

Any breach or infringement will result in liability for damages.

All rights reserved concerning patent or utility model application.



Contents

1	Overview of throttle valves type ED, restrictor check valves type RD and RDF	4
2	Available versions, main data	5
3	Parameters	8
3.1	General	8
4	Dimensions	11
5	Installation, operation and maintenance information	12
5.1	Intended application	. 12
5.2	Assembly information	. 12
5.3	Operating instructions	.13
5.4	Maintenance information	.13



1

Overview of throttle valves type ED, restrictor check valves type RD and RDF

Throttle valves are a type of flow valve. They affect the flow rate for single and double-acting consumers.

The restrictor check valve type RD and RDF combines the function of a flow valve with a check valve. It regulates in one flow direction and permits free flow in the other direction. Types ED and RD are adjustable.

The valve type ED, RD and RDF can be integrated directly in the line.

Features and benefits:

- Sensitively adjustable
- Wear-resistant

Intended applications:

• General hydraulic systems





2

Available versions, main data

Type ED

Single throttle valve

Circuit symbol:

Section view:





- 1 Manual adjustment
- 2 Adjusting spindle (coding K) adjustable with tool (pin)
- 3 Annular gap throttle, consisting of bore edge and truncated cone (hardened)

Type RD

Restrictor check valve

Circuit symbol:

Section view:





- 1 Check valve plate: closed position (throttled)
- 2 open position (free flow)
- 3 Bearing screw for check valve with travel stop journal to prevent unscrewing of adjusting spindle
- 4 Annular gap throttle, consisting of bore edge and truncated cone (hardened)



Type RDF

Restrictor check valve with fixed throttle

Circuit symbol:

Section view:





1 RDF 11: Orifice M4x0.4 ... 1.8 RDF 21: Orifice M5x0.5 ... 2.0 Orifice secured with screw locking RDF 31 to 51: orifice disc Ø0.8 ... 5.5 with retaining screw

Order coding example:





Table 1 Basic type and size

Basic type and size	Description	Volumetric flow Q (lpm)	Pressure p _{max} (bar)	Thread (BSPP)	Circuit symbol			
ED 11	Single throttle valve	12	500	G 1/4				
ED 21	$F \leftrightarrow G$ throttling in both flow directions	30		G 3/8				
ED 31		60		G 1/2	F F G			
ED 41		80		G 3/4				
ED 51		130		G 1				
RD 11, RD 112	restrictor check valve	12	500	G 1/4				
RD 11 JIS	$F \rightarrow G$ free flow $F \leftarrow G$ throttled	12		G 1/4 JIS				
RD 21		30		G 3/8	<u> </u>			
RD 21 JIS	Type RD 112 - precision throttle	30		G 3/8 JIS	F G			
RD 31	see <u>Chapter 3, "Parameters"</u>	60		G 1/2				
RD 41	"Characteristic curves"	80		G 3/4				
RD 51		130		G 1				
RDF 11/	Throttle check valve with fixed	12	500	G 1/4				
RDF 21/	throttle $F \rightarrow G$ free flow	30		G 3/8				
RDF 31/	$F \leftarrow G$ throttled	60		G 1/2	F G			
RDF 41/		80		G 3/4				
RDF 51/		130		G 1				



Thread in accordance with DIN EN ISO 228-1, SAE J 514 (-UNF) or JIS B 2351-1.

Table 2 Fixed throttle for type RDF

	\varnothing (mm	Ø (mm)												
	0.4	0.5	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0				
RDF 11/	•	•	•	•	•	٠	•	•	•					
RDF 21/		•	٠	•	•	٠	•	•	•	•				
	\varnothing (mm)												
	0.8	1.0	1.2	1.4	1.6	1.8	2.0	2.5	3.0	3.5	4.0	4.5	5.0	5.5
RDF 31/	•	•	•	•	•	•	•	•	•	•	•	•		
RDF 41/	•	•	•	•	•	•	•	٠	•	•	٠	•	•	•
RDF 51/	•	•	•	•	•	•	•	•	•	•	•	•	•	•

Table 3 Adjustment for type ED and RD

Coding	Description
No designation	Manual (wing bolt/lock nut)
К	With tool (adjusting spindle/lock nut)



Parameters

3.1 General

3

Designation	Throttle valves, throttle check valves							
Design	Slotted throttle, annular gap throttle, orifice nozzles							
Model	Housing version							
Material	Steel; hardened, ground functional inner parts Electrogalvanised surface							
Installation position	As desired							
Volumetric flow direction	Type RD, RDF:free volumetric flow $F \to G$ throttled $G \to F$ Type ED:throttled $G \to F, F \to G$							
Hydraulic fluid	Hydraulic oil: according to DIN 51524-1 Part 1 to 3; according to DIN ISO 3448 Viscosity limits: min. approx. 4, max. approx. 1500 mm²/s opt. operation approx. 10 500 mm²/s. Also suitable for biologically degradable hydraulic fluids type HEPG (polyalkylene glycol) and HEES (synthetic ester) at operating temperatures up to approx. +70°C.							
Cleanliness level	ISO 4406 21/18/1519/17/13							
Temperatures	Ambient: approx40 +80°C, Fluid: -25 +80°C, Note the viscosity range! Permissible temperature during start: -40°C (observe start-viscosity!), as long as the service temperature is at least 20K higher for the following operation. Biologically degradable pressure fluids: Observe manufacturer's specifications. By considera- tion of the compatibility with seal material not over +70°C.							



Characteristic curves

Type ED and RD Throttle direction $\mathbf{G} \rightarrow \mathbf{F}$

Oil viscosity approx. 54 mm²/s





Q flow rate (lpm); #p flow resistance (bar)

- 1 One revolution
- 2 Two revolutions
- 3 Full opening





Q flow rate (lpm); Δp flow resistance (bar)

L	1	revo	lution

2 2 revolutions

3 Full opening

Type ED 41, RD 41



Q flow rate (lpm); Δp flow resistance (bar)

- 1 1 revolution
- 2 2 revolutions
- 3 Full opening





Q flow rate (lpm); Δp flow resistance (bar)

- 1 1/8 revolution
- 2 1/4 revolution
- 3 1 revolution
- 4 1 1/4 revolutions
- 5 1 1/2 revolutions
- 6 1 3/4 revolutions

Type ED 31, RD 31



Q flow rate (lpm); Δp flow resistance (bar)

- 1 1 revolution
- 2 2 revolutions
- 3 Full opening

Type ED 51, RD 51



- 1 1 revolution
- 2 2 revolutions
- 3 Full opening



Characteristic curves

Type RDF Throttle direction ${\rm G} \rightarrow {\rm F}$

Type RD and RDF Free flow $F \rightarrow G$

Oil viscosity approx. 54 mm²/s



 $\Delta p \approx 3$ bar at approx. 0.5 Q_{max} $\Delta p \approx 8$ bar at approx. Q_{max} For Q_{max} see Table 1 in <u>Chapter 2</u>, "Available versions, main data"

Weight

Туре	
ED 11	= 180 g
ED 21	= 220 g
ED 31	= 350 g
ED 41	= 660 g
ED 51	= 840 g
RD 11, RD 112	= 180 g
RD 11 JIS	= 180 g
RD 21	= 220 g
RD 21 JIS	= 220 g
RD 31	= 350 g
RD 41	= 660 g
RD 51	= 840 g
RDF 11/	= 180 g
RDF 21/	= 220 g
RDF 31/	= 350 g
RDF 41/	= 660 g
RDF 51/	= 840 g



4 Dimensions

All dimensions in mm, subject to change.

Type ED.. and RD..





Type RD../..

E



Coding	Ports F and G (BSPP)	L	Η	H1	h	D	В	SW	SW1	Adjustment travel s approx.	Revolution approx.
ED 11(K), RD 11(K), RDF 11/	G 1/4	52	2.5	15.5	6	2	32	24	10	2.25	2 1/4
RD 112	G 1/4	52	23.5	15.5	6	2	32	24	10	2.25	2 1/4
RD 11 JIS	G 1/4 JIS	52	23.5	15.5	6	2	32	24	10	2.25	2 1/4
ED 21(K), RD 21(K), RDF 21/	G 3/8	52	24	16.5	6	2	32	27	10	2.5	2 1/2
RD 21 JIS	G 3/8 JIS	52	24	16.5	6	2	32	27	10	2.5	2 1/2
ED 31(K), RD 31(K), RDF 31/	G 1/2	62	32.5	21.5	7.5	3	45	32	13	3	3
ED 41(K), RD 41(K), RDF 41/	G 3/4	72	41	25.5	7.5	3.5	55.5	41	17	4.5	3
ED 51(K), RD 51(K), RDF 51/	G 1	82	46.5	26.5	7.5	4	61	46	19	4.5	3

SW = a/f



5 Installation, operation and maintenance information

5.1 Intended application

This valve is intended exclusively for hydraulic applications (fluid engineering). The valve meets high technical safety standards and regulations for fluid.

The user must observe the safety measures and warnings in this documentation.

Essential requirements for the product to function correctly and safely:

- All information in this documentation must be observed. This applies in particular to all safety measures and warnings.
- The product must only be assembled and put into operation by qualified personnel.
- The product must only be operated within the specified technical parameters. The technical parameters are described in detail in this documentation.
- The operating and maintenance manual of the specific complete system must also always be observed.

If the product can no longer be operated safely:

Remove the product from operation and mark it accordingly. It is then not permitted to continue using or operating the product.

5.2 Assembly information

The product must only be installed in the complete system with standard connection components that comply with market requirements (screw fittings, hoses, pipes, etc.).

The hydraulic system must be shut down correctly prior to dismounting; this applies in particular to hydraulic systems with hydraulic accumulators.

Danger

Risk to life caused by sudden movement of the hydraulic drives when dismantled incorrectly! Risk of serious injury or death.

- Depressurise the hydraulic system.
- Perform safety measures in preparation for maintenance.



5.3 Operating instructions

Product configuration and setting the pressure and flow rate

The statements and technical parameters in this documentation must be strictly observed. The instructions for the complete technical system must also always be followed.

Note

- Read the documentation carefully before usage.
- The documentation must be accessible to the operating and maintenance staff at all times.
- Keep documentation up to date after every addition or update.

Caution

Risk of injury due to unexpected movement processes in the machine due to incorrect flow setting! Risk of minor injury

- Be prepared for unexpected, fast movements. On changing the flow settings, consumers will move more slowly or more quickly.
- Always monitor the pressure gauge when setting or changing the flow.

Purity and filtering of the hydraulic fluid

Fine contamination can significantly impair the function of a hydraulic power pack. Contamination can cause irreparable damage.

Examples of fine contamination include:

- Metal chips
- Rubber particles from hoses and seals
- Dirt due to assembly and maintenance
- Mechanical debris
- Chemical ageing of the hydraulic fluid

Note

Fresh hydraulic fluid from the drum does not always have the highest degree of purity. Under some circumstances the fresh hydraulic fluid must be filtered before use.

Pay attention to the cleanliness level of the hydraulic fluid in order to maintain faultless operation. (Also see cleanliness level in <u>Chapter 3</u>, "Parameters".)

5.4 Maintenance information

This product is largely maintenance-free.

Conduct a visual inspection at regular intervals, but at least once per year, to check if the hydraulic connections are damaged. If external leakages are found, shut down and repair the system.

Clean the device surface of dust deposits and dirt at regular intervals, but at least once per year.



Further information

Additional versions

- Restrictor check valve type BC Screw-in valve: D 6969 B
- Restrictor check valve type BE Screw-in valve: D 7555 B
- Throttle valve and throttle check valve type Q, QR and QV: D 7730
- Throttle valve and throttle check valve type FG: D 7275
- Throttle valve and throttle check valve type CQ, CQR and CQV: D 7713

HAWE Hydraulik SE

Streitfeldstraße 25 | 81673 München | Postfach 80 08 04 | 81608 München | Germany Tel +49 89 379100-1000 | Fax +49 89 379100-91000 | info@hawe.de | www.hawe.com